ADBRI Cement
ABN 29 075 095 822

# Cement Test Certificate

Final

*Gate 7 Foreshore Road, Port Kembla*
*NSW 2505*
*PO Box 230, Port Kembla NSW 2505*
*T: +61 2 4276 4888*
*F: +61 2 4276 4399*
*www.adbri.com.au*

**Product Certified:** Type SL Shrinkage Limited Cement
**Test Certificate Number:** 260506
**Customer:** Adbri Cement, Port Kembla Plant, NSW
**Sample Code:** B0c9b97
**Sample Date:** 09/07/2026

| Nominal Blend | Requirements | Result |
|---|---|---|
| Clinker | | >85 % |
| Ground Granulated Iron Blast-Furnace Slag | | Nil |
| Mineral Addition | Max 7.5 % | <7.5 % |
| Calcium Sulphate | | 4-8 % |
| Minor Additional Constituents | Max 5 % | <5 % |

| Reportable Property | Test Method | Requirements of AS3972 | Result |
|---|---|---|---|
| 3 Day Strength | AS/NZS2350.11 | N/R | 36.1 MPa |
| 7 Day Strength | AS/NZS2350.11 | Min 35.0 MPa | 52.1 MPa |
| 28 Day Strength | AS/NZS2350.11 | Min 45.0 MPa | 63.4 MPa |
| Initial Set Time | AS/NZS2350.4 | Min 45 min | 120 min |
| Final Set Time | AS/NZS2350.4 | Max 600 min | 225 min |
| Soundness | AS/NZS2350.5 | Max 5 mm | 0 mm |
| Sulfuric Anhydride content ($SO_3$) | AS2350.2 | Max 3.5 % | 2.5 % |
| Chloride Ion | BH-TM-0507 | Max 0.10 % | 0.019 % |
| Shrinkage 28 Days | AS2350.13 | Max 750 µstrain | 630 µstrain |
| **Other Properties** | | | |
| $SiO_2$ | AS2350.2 | N/R | 19.0 % |
| $Al_2O_3$ | AS2350.2 | N/R | 5.1 % |
| $Fe_2O_3$ | AS2350.2 | N/R | 3.1 % |
| CaO | AS2350.2 | N/R | 63.6 % |
| MgO | AS2350.2 | N/R | 1.4 % |
| $Na_2O$ Equivalent | AS2350.2 | N/R | 0.3 % |
| Loss on Ignition | AS2350.2 | N/R | 4.5 % |
| Fineness Index | AS/NZS2350.8 | N/R | 365 m²/kg |
| Normal Consistency | AS/NZS2350.3 | N/R | 27.8 % |

***This document shall not be reproduced except in full.***

**REMARKS**

These test result apply specifically to the sample as received at the Adbri Cement Birkenhead Laboratory (Accreditation number: 252), 62 Elder Rd Birkenhead SA 5015.
This despatch grab sample complies to the requirements of AS3972:2010, Type SL Cement.
N/R = No Requirement

NATA
WORLD RECOGNISED ACCREDITATION

Accredited for compliance with ISO/IEC 17025 - Testing.

Approved Signatory
M. Wythe

**Issue Date:** 30/09/2026